

No. ST/1508

Dated: 04-11-2023

TO WHOM IT MAY CONCERN

It is certified that I, **Er. Vikas Bhardwaj (Prop. M/s Continental Foundations)** have personally visited the school buildings of "**Maharishi Dayanand Adarsh Vidyalaya, Sector: 22-A, Chandigarh**" along with the school representative "**Mr. Sandeep Pundeer**".

On the site visit it was observed that the building is a constructed upto 3 stories (Ground floor, first floor & part of second floor), the same is constructed as a Brick structure building with few RCC Columns. On site visit various Tests such as *Rebound Hammer and Ultrasonic Pulse velocity* were carried out for this building and the results were found to be Satisfactory. The school building has been constructed in year 1979-82 as per the codal provisions prevalent at that time.

On the visual inspection there were no major structural/deflection cracks observed. As on date the buildings is fit for running an educational institute, provided it is properly maintained. This certificate is valid for a period of one year.

For M/s Continental Foundations

(ADMINISTRATOR)



1 STRUCTURAL STABILITY CERTIFICATE



**PHOTOGRAPH OF MAHARISHI DAYANAND ADARSH VIDYALYA,
SECTOR: 22-A, CHANDIGARH.**

